



No. HHS/Quotation/01/2025

Dated, Halhali, the 10.12.2025

NOTICE INVITING QUOTATION

Sealed quotations are hereby invited from **registered and experienced firms/agencies** for the supply/installation/ of Fire safety equipment as mentioned in the Annexure-1 at **Halhali Class XII School**.

Details are as follows:

1. **Name of Work / Item:** supply/installation/ of Fire safety equipment
2. **Last date & time of submission:** 09.01.2026 (2.00 PM)
3. **Place of submission:** Office of the Principal, Halhali Class XII School
4. **Date & time of opening of quotation:** 21.01.2026 (12.00 Noon)
5. **Eligibility:**
 - o The firm must be registered.
 - o GST registration and relevant documents must be enclosed.
 - o Experience in similar work is desirable.

The quotation should be submitted in a sealed envelope clearly superscribed as

“Quotation for supply/installation/ of Fire safety equipment at Halhali Class XII School”.

The undersigned reserves the right to accept or reject any or all quotations without assigning any reason.

By order

10.12..2025

(Sanjib Kumar Debnath)
Vice Principal
Halhali Class XII School

Annexure-1

- 01 (one) No. Co2 fire extinguisher -4.5 kg capacity to be installed near electric panel board & 02 (two) Nos. Co2 fire extinguisher 2 kg capacity to be installed.
- 02 (two) Nos. ABC fire extinguisher -06 kg capacity to be installed.
- 03 (three) Nos. DCP extinguisher 06 kg capacity to be installed.
- 02 (two) point hose reel hose along with a pressure gauge to be installed. Hose reel length 30 mtr.
- Hose reel nozzle diameter 19 mm.
- 02 (two) manually operated electronic fire alarm/manual call point to be installed with battery backup.
- Down comer 100 mm/4 inch diameter & 4.50 mm in thick (B-Class) to be installed in the building.
- 01 (one) landing valve floor wise& 02 (two) short branch. 02 (two) delivery hose & 01 (one) fireman axe to be installed near each hose reel point floor wise.
- Hose Box- 01 (one) double door hose box along with 01 (one) short branch, 02 (two) delivery hose & 01 (one) fireman axe to be installed near each hose reel point floor wise.
- Hose Box- 01 (one) double door hose box along with 01 (one) short branch, 02 (two) delivery hose & 01 (one) fireman axe to be installed near each hose reel point floor wise.
- Terrace level discharge of pump 900 LPM with a minimum pressure 3.5 kg/cm2.
- Terrace level head of pump 50 mtrs.
- Terrace level power supply should be in three phases.
- Auto pump controller to be installed in then terrace level pump along with an air release valve, pressure gauge & Pressure switch to be provided in the terrace level.
- Terrace tank capacity 10,000 ltrs. to be constructed in the building exclusively to the firefighting purposes.